



CITY OF FRISCO PURCHASING DIVISION

March 4, 2015
Addendum #2 – Clarifications
CSB #1503-046 Frisco 1 North Vertical Turbine Pump

Clarifications

Per discussion with attendees at the site visit:

The bid due date has been extended to Thursday, March 19, 2015 by 2:00pm CST.

1. Pump is to fit depth of the existing can.
2. Full face rubber gasket should be included in place of o-ring groove.
3. Clarification regarding bonding-no bid, payment or performance bond will be required with this bid. The pump warranty information should be included with this bid.
4. Include a new head shaft in your pricing submitted.

Bidders are required to acknowledge receipt of this addendum by initialing in the appropriate space on the bid document. The due date for this CSB has been extended to Thursday, March 19, 2015 by 2:00pm CST.

Vendors who may have already submitted a bid and feel this addendum may change their bid, may pick up their bid, and return it by the closing date. If picking up the bid is not feasible, any new bid submitted by your firm will supersede one previously submitted. If there is a discrepancy between this addendum and the bid, the addendum prevails.

Sincerely,

Daniel Ford, CPPO, CPPB
Purchasing Manager
City of Frisco